



**BUREAU
VERITAS**

Certificate of compliance

Applicant: **Shenzhen Senergy Technology Co., Ltd**
Room 405, Building A, Co-talent Creative Park, No.2, LiuXianRoad, Block 68,
Xin an Street, Bao' an District, ShenZhen.
China

Product: **Grid-tied photovoltaic (PV) inverter**

Model: **SE 6KTL, SE 8KTL, SE 10KTL, SE 12KTL, SE 15KTL**

Use in accordance with regulations:

Automatic disconnection device with three-phase mains surveillance in accordance with EN50549-1:2019 for photovoltaic systems with a three-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter.

Applied rules and standards:

EN 50549-1:2019

Requirements for parallel connection of installations with distribution networks - Part 1: Connection to an LV distribution network - Production of installations up to and including Type B

EN 50438:2013

Requirements for micro-generating plants to be connected in parallel with public low-voltage distribution networks

DIN V VDE V 0126-1-1:2006 (4.1 Functional safety)

Automatic disconnection device between a generator and the public low-voltage grid

At the time of issue of this certificate the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

Report number: **PV191119N046**

Certification Program: **NSOP-0032-DEU-ZE-V01**

Certificate number: **U20-0109**

Date of issue: **2020-02-28**

Certification body



Holger Schaffer



Certification body Bureau Veritas Consumer Products Services Germany GmbH accreditation to DIN EN ISO/IEC 17065

A partial representation of the certificate requires the written approval of Bureau Veritas Consumer Products Services Germany GmbH